



CLEAN BOILER

(Boiler Restorer)

- Ⓐ Provides energy savings by removing metal oxide and lime scale from the water side surface of the heat exchanger
- Ⓐ Restores the surface area of the heat exchanger to near original levels
- Ⓐ Maximizes heat exchanger efficiency
- Ⓐ Reduces noise from restricted fluid passageways
- Ⓐ Reduces maintenance costs
- Ⓐ Easy to use, most effective when used with a power-flushing device
- Ⓐ Concentration requirements: 1 liter (33.8 oz.) treats 10 liter or 2.5 U.S. Gallons of water
- Ⓐ Available in 1L (33 oz.) bottles

Dosage: 10-20%

Axi-Therm Clean Boiler can be used to restore operation on light to heavily fouled heat exchangers. Clean Boiler chemical is formulated to remove metal oxides and limescale deposits from the water side of boiler heat exchangers. Can be used on condensing and non-condensing boilers and is safe for use with all metals (steel, copper, and aluminum).

✉ info@axiomind.com

☎ (877)651-1815

🌐 WWW.AXIOMIND.COM





CLEAN BOILER TECHNICAL INFORMATION

DIRECTIONS:

Mix AXI-THERM CLEAN BOILER with demineralized water provided by an Axiom PUROPAL demineralizer at a concentration of 10 to 20%. Lower concentrations do not yield satisfactory results. Higher concentrations have no adverse effects. For light to medium cleaning use a 10% concentration and circulate for 2 to 4 hours. For heavy cleaning requirements and best results, circulate a 20% mixture through the boiler for 6 to 8 hours.

To avoid the re-formation of deposits, clean the system with AXI-THERM CLEAN 5 OR 10 and refill the system with AXI-THERM PROTECT 1 inhibitor. Do not use in potable water systems. Do not ingest. Do not dispose of waste through the environment. Keep out of reach of children.



BEFORE



AFTER

SKU	Purpose	Bottle Size	Treatment Volume	Case Qty
AXTH-BOILER-1L	Boiler Water Side Cleaner	1L (33.8oz)	5 to 10 litres (1.32 to 2.64 gal)	10

ACCESSORIES:

- AXTH- Water Test** -- Axi-Therm Boiler Water Quality Titration Test Kit
- PruoPal-1** -- Disposable Demineralizer Cartridge

Project

Location

Consultant

Contractor

Unit Tag

Sales Agent